



**ANSI C119.1
Impact Test Data**

**4.2.4
Summary Sheet**

Part #	PED11-1/0SS	PED21-1/0SS	SLSS21-10SS
Cable Size - Maximum Size	1/0 AWG	#4 AWG	#4 AWG
Cut Ring (If Applicable)	N/A	#2-#4	#2-#4
Insulation Type	RHW, RW90 EP, USE, RW90 XLPE, TWU or XHHW	RHW, RW90 EP, USE, RW90 XLPE, TWU or XHHW	RHW, RW90 EP, USE, RW90 XLPE, TWU or XHHW
Screw Size	3/8-24	3/8-24	3/8-24
Number of Screws	1	1	1
Torque (in-lb)	50	45	45
Cold Conditioning			
Immerse in 305 mm (1ft) of water for 4 hr.			
----- Dielectric withstand test @ 2.2 kV AC for one minute per 6.4.1.5 without breakdown	Passed	Passed	Passed
Heat Conditioning			
Immerse in 305 mm (1ft) of water for 4 hr.			
----- Dielectric withstand test @ 2.2 kV AC for one minute per 6.4.1.5 without breakdown	Passed	Passed	Passed